

ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685

	Ac flash hazard! Act flash hazard! Fullow requirements in MFM_TO di to saft with propriations and appropriate MFE, full-un-to comply care result in death or lifery!
--	--

4490E Dangar Label Nos Ara Elash 4" V 4" Adhasiya

44895 Danger Label, Nec Arc Flash, 4" X 6", Adhesive	
Catalog Number	44895
Manufacturer	ldeal
Description	Self-Sticking Nec Arc Flash Protection Label, Polyester, 6 In Length, 4 In Width, Red and Black Legend Color, Danger Legend, White Background, Package: 5/Bag, National Electric Code 110.16
Weight per unit	N/A
Product Category	Markers & Marking Tapes
eatures	
Legend	DANGER
laterial, Color, and Finish	
Background Color	White
Legend Color	Red And Black
mensions and Weight	
Length	6
Width	4
escriptions	
Description	DANGER LABEL, NEC ARC FLASH, 4" X 6", ADHESIVE
extra long description	IDEAL 44-895 Flash Protection Label
Features	Our Flash Protection Labels and Signs can be used to warn qualified persons of potential electric arc flash hazards in areas that are likely to require examination, adjustment, servicing or maintenance while energized. All markings are located where they will be clearly visible. Labels are self-sticking and are ideal for switchboards, panel boards, industrial control panels and motor control centers. It meets NFPA standards. National Electric Code 110.16 Flash Protection: Switchboards, panel boards, industr
Long Description	Self-Sticking NEC Arc Flash Protection Label, Polyester, 6 IN Length, 4 IN Width, Red And Black Legend Color, Danger Legend, White Background, Package: 5/Bag, National Electric Code 110.16
Product Type Special Features	Flash Protection Label, Ideal, Arc, Self-Sticking, National Elec National Electric Code 110.16 Flash Protection: Switchboards, panel boards, industrial control panels and motor control centers, in other than dwelling occupancies, that are likely to require examination, adjustment, servicing or maintenance while energized, shall be field marked to warn qualified persons of potential electric arc flash hazards; The marking shall be located so as to be clearly visible to qualified persons before examination, adjustment, servicing or maintenance of the

equipment.



Elliott Electric Supply

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685

N/Amiltontile	ar Intarmaati	00
IV/I a l'II I I l'al' I I I I l	46 IIIII/IIIIIIAII	
Manufactur		

Brand	ldeal	
GTIN	00783250547357	
Manufacturers Part Number	44-895	
UPC	783250547357	

Taxonomies, Classifications, and Categories

Category Description	SAFETY PRODUCTS
Туре	Self-Sticking NEC Arc Flash Protection Label

Packaging

okugirig	
Carton	1
Weight Per each	0

Uses, Certifications, and Standards

standard	National Electric Code 110.16	
----------	-------------------------------	--