

Elliott Electric Supply

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685



B22SHAHDG10 BLTD 3-1/4X1-5/8X120 12GA HDG BK2BK SLTD, 2" CNTR Cooper B-Line/Cable Tray

B22SHAHDG10 Cooper P. Lipe/Cable Tray
Cooper B-Line/Cable Tray Eaton B-Line Series Strut Back-to-Back Welded Channel, 1.62" H
120" L X 1.62" W, Steel, Hot-Dipped Galvanized, Sha, 12 Gauge
3.6 (lbs/each)
Channel & Strut
12.0000 IN X 1.6250 IN X 3.2500 IN
12
1-1/8 In Length X 9/16 In Width
Hot-Dipped Galvanized
Cold Formed Low Carbon Steel
ASTM A123
3-1/4 In
10 ft
1-5/8 in
Strut
Strut channel
BLTD 1-5/8X3-1/4X120 12GA HDG BK2BK SLTD, 2" CNTR
B-LINE B22SHA-120HDG CHNL, 1 5/8" X
Eaton offers a wide range of back to back and welded configured strut combinations for a variety of support applications.
Eaton B-Line series strut back-to-back welded channel, 1.62" H x
120" L x 1.62" W, Steel, Hot-dipped galvanized, SHA, 12 Gauge
CHNL, 1 5/8" X 1 5/8", B to B, 9/16" X 7/8" Slots, 12 Ga,
Unistrut
2 In Center Spacing
Eaton
00781011843281
B22SHA-120HDG
781011843281



Elliott Electric Supply

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685

Taxonomies, Classifications, and Categories

Category Description	STRUT CHANNEL
Туре	Strut back-to-back welded channel
Availability	
Status	Inactive
Packaging	
Carton	1
Weight	3.64 Lb/Ft
Weight Per each	3.6
Uses, Certifications, and Standards	
Application	UtilityResidential Bldgs & Facilities - Residential Bldgs & Facilities - OtherGeneration - Conventional Energy - Conventional EnergyDatacenters - IT Space: Enterprise / Server Room / Network ClosetOther IT and Datacom - Other InfrastructuresInd Facilities & Factories - Facility - OtherCommercial / Institutional Buildings / Structures - Commercial/Inst Bldg Strctures - AftermarketDatacenters - Datacenters - OtherGeneration - Renewable Energy - Alternative EnergyCommercial / Institutional Buildings / Structu
standard	Not Applicable