

## ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685



## **TRSGFH20W Gfci TR HG Self Test Duplex 20A 125V WH** *Eaton Wiring Devices*

3E2		
Catalog Number	TRSGFH20W	
Manufacturer	Eaton Wiring Devices	
Description	Eaton Hospital Grade Gfci Receptacle, Tamper Resistant,	
	Self-Test, #14 - 10 Awg, 20A, Residential, Commercial, Flush, 125	
	V, Gfci, Back and Side Wire, White, Brass, Receptacle, Tamper	
	Resistant, Nylon, 5-20R, Two-Pole, Three-Wire, Grounding	
Weight per unit	0.4050 (lbs/each)	
Product Category	Gen Purpose Recept & Surge Pro	
Features		
amperage rating	20A	
dimensions	2.8130 IN X 2.0000 IN X 4.6250 IN	
media	Yes	
Voltage Rating	125V	
Descriptions		
Description	GFCI TR HG SELF TEST DUPLEX 20A 125V WH	
extra long description	EWD TRSGFH20W GFCI TR HG Self Test	
Features	Tested to the highest standards to provide dependable,	
	state-of-the-art protection suitable for residential, commercial,	
	and industrial settings, Eaton's Ground Fault Circuit Interrupter	
	(GFCI) receptacles are designed to recognize a ground fault in	
	your wiring and immediately break the flow of electricity, thus	
	protecting you from electrical shock. Additionally, they prevent	
	resetting if, once tripped, the ground fault renders the device no	
L D	longer functional. When combined with Eaton's Arc Fault Circuit	
Long Description	Eaton hospital grade GFCI receptacle, Tamper	
	resistant,Self-test,#14 - 10 AWG,20A,Residential,Commercial,Flush,125 V,GFCI,Back and side	
	wire, White, Brass, Receptacle, Tamper	
	resistant,Nylon,5-20R,Two-pole, three-wire, grounding	
Product Type	Gfci TR HG Self Test Duplex 20A 125V WH	
Special Features	Hospital grade GFCI	
Manufacturer Information	g	
Brand	Eaton	
GTIN	Eaton 00032664740121	
Manufacturers Part Number		
UPC	TRSGFH20W	
UFU	032664740121	



## ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685

<b>Taxonomies</b>	Classifications,	and Categori	ies
-------------------	------------------	--------------	-----

environmental conditions

standard

Industrial GFCI devices
Hospital grade GFCI receptacle
1
10
0.405
Commercial / Institutional Buildings / Structures - Commercial /

Tamper resistant NOM,cULus Listed

Institutional Buildings / Structures - Other